

KEMA TYPE TEST CERTIFICATE OF COMPLETE TYPE TESTS

Manufacturer	JSC "Electrotechnical Factories "Energomera"
Contact person	Ms. Olga Minaeva
Address	415, Lenina str.
Postal code, City	355029, Stavropol
Country	Russia
Production site	Measuring Equipment Factory "Energomera"
Address	217, Gagarina Str.
Postal code, City	357106, Nevinnomyssk
Country	Russia
Instrument	Electronic three-phase four-wire energy meter Transformer connected
Mark - Type	CE308
Register	LCD
Accuracy Class	Active: 0,5s/C
Measurement range	57,7/100 V or 230/400 V, 5(10) A, 50 Hz active : 8000 or 4000 imp./kWh
Use	Indoor, not sensitive to phase sequence
Protection Class	II
Registry method	Bi-directional method of separate registers: received- and delivered energy of the whole connection is added to separate registers

The energy meter meets the requirements of:
IEC 62052-11:2003, IEC 62053-21:2003.

Based on a non-recurrent examination.

The results are recorded in our test report with reference 1085-20 V2.

KEMA B.V.



Bas Verhoeven
Director, High-Voltage
Laboratory

Arnhem, 8 June 2020